



Fort Mill
SOUTH CAROLINA

Town of Fort Mill Policies and Procedures (Building Inspection Division)

Effective Date: 1-1-2020

Knox Box Placement Policy

The required Knox Box must be installed with-in 3' to the left or right of the main entrance and at 5' above the threshold of the entrance door. The Knox Box must be keyed the TOFM key for emergency access. The required Knox Box must be installed prior to the Final Inspection for the Certificate of Occupancy. This must be verified and approved by the TOFM Fire Marshal.

Submittal Requirements: Knox Box Policy (Formatted July 1,2020)

P.O. BOX 159 • 200 TOM HALL STREET • FORT MILL, SC 29715

E-MAIL inpsections@fortmillsc.gov • TELEPHONE (803) 547-2034 • FAX (803) 547-2126