



## **Town of Fort Mill Policies and Procedures (Building Inspection Division)**

**Effective Date: 3-1-2020**

### **Gas Pipe Pressure Test Inspection Procedures**

The Gas Pipe Pressure Test Inspection shall be performed on any/all new/existing Gas Piping systems or portion thereof being put into service as a part of a Rough-In or Mechanical Inspection from the inlet (Meter) to the termination shut-off (Appliance). This Gas Pipe Pressure Test Inspection shall also be verified **again** at the time of the Permanent Power Inspection (New Construction) and a written release will be sent to the local Gas Provider for connection. The Gas Pipe Pressure Test Inspection is a required to be requested by the contract at the time of their inspections.

The Gas Pipe Pressure Test Inspection shall be performed at 20 lbs. PSI for not less than 15 minutes. A two PSI tolerance +/- shall be allowed due to extreme hot or cold temperature (below 32°, above 95°) for a 24-hour periods of time.

*Submittal Requirements: Gas Pipe Pressure Test Inspection Procedure (Formatted July 1,2020)*

**P.O. BOX 159 • 200 TOM HALL STREET • FORT MILL, SC 29715**

**E-MAIL [inpspections@fortmillsc.gov](mailto:inpspections@fortmillsc.gov) • TELEPHONE (803) 547-2034 • FAX (803) 547-2126**

**P.O. BOX 159 • 200 TOM HALL STREET • FORT MILL, SC 29715**  
**E-MAIL [inpsections@fortmillsc.gov](mailto:inpsections@fortmillsc.gov) • TELEPHONE (803) 547-2034 • FAX (803) 547-2126**