



Fort Mill
SOUTH CAROLINA

Town of Fort Mill Policies and Procedures (Building Inspection Division)

Effective Date: 11-15-2019

Fire Fighting-Emergency Vehicle Access Procedure (During Construction)

No project in the Town of Fort Mill will be allowed to commence without an approved water source capable of providing the minimum water pressure/volume required to support the firefighting efforts by Town of Fort Mill's Fire Department's adopted Codes. An Emergency Vehicle Access Road (EVAR) must be capable supporting an 80,000 lb. emergency vehicle as required by adopted Town of Fort Mill Codes and Ordinance.

Submittal Requirements: Fire Fighting-Emergency Vehicle Access Procedure (Formatted July 1, 2020)

P.O. BOX 159 • 200 TOM HALL STREET • FORT MILL, SC 29715

E-MAIL inpspections@fortmillsc.gov • TELEPHONE (803) 547-2034 • FAX (803) 547-2126