



Town of Fort Mill Policies and Procedures (Building Inspection Division)

Effective Date: 1-6-2020

Commercial Building Temporary Power

Permanent/Temporary Power can be released to commercial building/tenant spaces when the building/space meets the minimum requirement for Commercial Building Temporary Power. The minimum requirements shall be as follows:

- 1) **All** meter panels, service enclosure, service grounding/bonding shall be installed and complete.
- 2) **All** landing in the distribution panels must be complete and all breakers must be installed.
- 3) **All** distribution panels shall be **lockable** and **ONLY** the job **Electrician** shall have control of the key.
- 4) **All** devices on the circuit that are to be energized must be in place or protected from accidental contact to above 7' above the highest point of contact.
- 5) **All** panels that are likely to become energized that require inspection will require a **lockout/tagout** procedure prior to inspection.

Submittal Requirements: Commercial Perm-Temp Power Policy (Formatted July 1,2020)

P.O. BOX 159 • 200 TOM HALL STREET • FORT MILL, SC 29715
E-MAIL inspections@fortmillsc.gov • TELEPHONE (803) 547-2034 • FAX (803) 547-2126