



## **Town of Fort Mill Policies and Procedures (Building Inspection Division)**

**Effective Date: 9-15-2018**

### **Back to Back Electrical Service**

The electrical meter and electrical panel installation will be considered back-to-back installation and will not require an external disconnect until the service entrance cable (SEC) between the electrical meter and the electrical panel exceeds 10' in length. When the SEC exceeds 10' in length, a protected exterior disconnect shall be installed and the electrical panel will be considered a sub-panel and must be installed to meet the minimum requirement of the currently adopted Electrical Code for sub-panel installation.

*Submittal Requirements: Back-to-Back Electrical Service Policy (Formatted July 1, 2020)*

**P.O. BOX 159 • 200 TOM HALL STREET • FORT MILL, SC 29715**

**E-MAIL [inpspections@fortmillsc.gov](mailto:inpspections@fortmillsc.gov) • TELEPHONE (803) 547-2034 • FAX (803) 547-2126**

**P.O. BOX 159 • 200 TOM HALL STREET • FORT MILL, SC 29715**

**E-MAIL [inpsections@fortmillsc.gov](mailto:inpsections@fortmillsc.gov) • TELEPHONE (803) 547-2034 • FAX (803) 547-2126**