



Town of Fort Mill Policies and Procedures (Building Inspection Division)

Effective Date: 3-27-2019

Saw Pole (Temp. Construction Power Service)

Saw Pole shall be provided with no less than a 100 amp meter base and electrical panel with at least one (1) 20 amp breaker to supply power to at least one (1) 20 amp GFCI receptacle. There shall be provided at least one (1) 8' driven ground rod as per code. These devices shall be installed on a treated 4" x 4" post a minimum 18" in the ground with brace pole to support the imposed load. Post height for underground service shall be a minimum of 60" with center of the site glass for the meter a minimum of 48".

Submittal Requirements: Saw Pole (Construction Power Service) Policy (Formatted July 1,2020)

P.O. BOX 159 • 200 TOM HALL STREET • FORT MILL, SC 29715
E-MAIL inpsections@fortmillsc.gov • TELEPHONE (803) 547-2034 • FAX (803) 547-2126